

Errata to 2007 Edition National Electrical Safety Code®

Correction Sheet
Issued 1 February 2009

Copyright © 2009 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 2009. Printed in the United States of America.

This correction sheet may be freely reproduced and distributed in order to maintain the utility and currency of the underlying Standard. This correction sheet may not be sold, licensed, or otherwise distributed for any commercial purposes whatsoever. The content of this correction sheet may not be modified.

The following correction should be made:

Page 120: There is an error in Figure 234-4(a). The text associated with “ V_2 ” in the legend is incorrect. It should read: “vertical clearance above land required by Rule 232C (Table 232-1 or 232-2)” and not “vertical clearance above a building required by Rule 232C (Table 232-1 or 232-2).”




Figure 234-4(a)—Clearance envelope for grain bins filled by permanently installed augers, conveyors, or elevators