

# Correction to IEEE Standard for Qualification of Class 1E Transformers for Nuclear Power Generating Stations

Sponsor  
**Transformers Committee  
of the  
IEEE Power Engineering Society**

Correction Sheet

**Issued 7 April 1999**

Copyright © 1999 by the Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 1999. Printed in the United States of America.

This correction sheet may be freely reproduced and distributed in order to maintain the utility and currency of the underlying Standard. This correction sheet may not be sold, licensed or otherwise distributed for any commercial purposes whatsoever. The content of this correction sheet may not be modified.

The following correction should be made:

**Pages 14–18:** Insert the following note above the figure title in Figure A2 and Figure A3:

NOTE—To calculate life expectancy, use the equations in A2.2 and A3.4.1 (or consult IEEE Std C57.96-1989) since this figure is for illustration purposes only.