

Correction to IEEE Standard for Metal-Clad Switchgear

Sponsor

Switchgear Committee
of the
IEEE Power Engineering Society

Correction sheet
Issued 1 August 2000

Copyright © 2000 by the Institute of Electrical and Electronics Engineers, Inc.

All rights reserved. Published 2000. Printed in the United States of America.

This correction sheet may be freely reproduced and distributed in order to maintain the utility and currency of the underlying Standard. This correction sheet may not be sold, licensed or otherwise distributed for any commercial purposes whatsoever. The content of this correction sheet may not be modified.

1 August 2000
SH94797

The incorrect data lines in Table 12 are lines 5 and 6, which show two 1200 A and two 2000 A breakers with 2500 A cumulative loading. The correct entry is a single line, indicating the combination of 1200 A and 2000 A breakers in a single vertical section with both breakers carrying load and an allowable cumulative load of 2500 A, as follows:

Table 12—Allowable cumulative loads

Circuit breaker continuous current rating (A)	Number of circuit breakers carrying load	Allowable cumulative load (A)*
1200	1	1200
1200	2	2000
2000	1	2000
2000	2	3200 [†]
1200 & 2000	2	2500
3000	1	3000

*Without forced ventilation.

[†]3200 A is a nonstandard rating (3000 A is preferred).