

IEEE Std C37.90.1™-2012

(Revision of
IEEE Std C37.90.1-2002)

Errata to IEEE Standard for Surge Withstand Capability (SWC) Tests for Relays and Relay Systems Associated with Electric Power Apparatus

Sponsor

Power System Relaying Committee

of the

IEEE Power & Energy Society

Copyright 2013 by the Institute of Electrical and Electronics Engineers, Inc. All rights reserved. Published 2013
Printed in the United States of America.

This correction sheet may be freely reproduced and distributed in order to maintain the utility and currency of the underlying Standard. This correction sheet may not be sold, licensed or otherwise distributed for any commercial purposes whatsoever. The content of this correction sheet may not be modified.

Correction Sheet

12 August 2013

Item 2) in 4.2 on page 5 should be corrected to read as follows:

- 2) into 1000 Ω load
 - i) rise time (10% to 90%) = 5 ns \pm 30%
 - ii) duration (above 50%) = 50 ns with a tolerance of -15 ns to + 100 ns
 - iii) peak voltage = 4 kV \pm 20%