

IEEE C57.12.34™-2004

**Errata to
IEEE Standard Requirements for Pad-Mounted,
Compartmental-Type, Self-Cooled, Three-Phase
Distribution Transformers (2500 kVA and Smaller)—
High-Voltage: 34 500 GrdY/19 920 Volts and Below;
Low Voltage: 480 Volts and Below**

Sponsor

**Transformers Committee
of the
IEEE Power Engineering Society**

Correction Sheet

Issued 15 August 2005

Copyright © 2005 by the Institute of Electrical and Electronics Engineers, Inc. All rights reserved. Published 2005.
Printed in the United States of America.

This correction sheet may be freely reproduced and distributed in order to maintain the utility and currency of the underlying Standard. This correction sheet may not be sold, licensed or otherwise distributed for any commercial purposes whatsoever. The content of this correction sheet may not be modified.

Page 28, Figure 13(b)—Low-voltage terminals, the Table should read as follows:

kVA Ratings	Low-voltage Ratings (volts)	Thread size^a	L^a Minimum
75–150	240, 208Y / 120	5/8 – 11 UNC – 2A	32 (1.250)
75–300	480, 480Y / 277	5/8 – 11 UNC – 2A	32 (1.250)
225-300	240, 208Y / 120	1 – 14 UNS – 2A	44 (1.750)
500	480, 480Y / 277	1 – 14 UNS – 2A	44 (1.750)
500	240, 208Y / 120	1 1/4 – 12 UNF – 2A	67 (2.625)
NOTES			
1—All dimensions are in millimeters (inches) and are minimums.			
2— Kilovolt-ampere ratings separated by a dash indicates that all ratings covered in this range as shown in 4.1 of this standard are included.			

^a If materials other than copper are used, larger thread size or length, or both, may be required.