

Accredited  
Standards  
Committee  
C2-1997

# National Electrical Safety Code®

Secretariat

**Institute of Electrical and Electronics Engineers, Inc.**

Approved 15 March 1996

**Institute of Electrical and Electronics Engineers, Inc.**

Approved 6 June 1996

**American National Standards Institute**

## 1997 Edition

First Printing

*Third Errata Sheet*

*22 April 1999*

The following was discovered after the first printing and should be corrected. Additional errata were noted on sheets published 3 September 1996 and 28 February 1997.

**Page 170:** In Rule 277, the reference to Section 25 should be replaced with references to Rules 250, 251, and 252. The revised Rule 277 should read as follows:

Insulators shall withstand all applicable loads specified in Rules 250, 251, and 252 except those of Rule 250C without exceeding the following percentages of their rated ultimate strength for the specified application:

This correction will be included in the next printing.