

**Tentative Interim Amendment 97-1
to the
National Electrical Safety Code
ANSI C2-1997**

27 March 1996

In accordance with Section 13 of its Procedures, the National Electrical Safety Code Committee has issued the following Tentative Interim Amendment (TIA) to ANSI C2, National Electrical Safety Code, 1997 Edition. The TIA was issued by the Secretariat on 27 March 1996, as a result of a proposal submitted by a member of the NESC Main Committee.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedure. It is interim because it is effective only between editions of the code. A TIA automatically becomes a Proposal of the proponent for the next edition of the code; as such, it is then subject to all the procedures of the standards-making process.

Rule 224B2 should read as follows:

2. Special circuits operating at voltages in excess of 90 V to ground and used for supplying power solely to communications equipment may be included in communication cables under the following conditions:

Rule 224B2 EXCEPTION should read as follows:

EXCEPTION: The requirements of Rule 224B2 do not apply to communication circuits where the transmitted power does not exceed 150 W.

Rule 344A should read as follows:

- A. Special circuits operating at voltages in excess of 90 V to ground and used for supplying power solely to communications equipment may be included in communication cables under the following conditions:

Rule 344A EXCEPTION should read as follows:

EXCEPTION: The requirements of Rule 344A do not apply to communication circuits where the transmitted power does not exceed 150 W.